

# Vic®-End II End of Run Fitting

## No. 67



10.21



### 1.0 PRODUCT DESCRIPTION

#### Available Sizes

- 1 ¼ – 3"/DN32 – DN80 with ½"/DN15, ¾"/DN20 or 1"/DN25 female threaded NPT or BSPT outlet.

#### Pipe Material

- Carbon Steel, Schedule 10, Schedule 40. For use with alternative materials and wall thicknesses please contact Victaulic.


#### Maximum Working Pressure

- Up to 365 psi/2500 kPa.

#### Function

- End of branchline elbow fitting for sprinkler connection.

### 2.0 CERTIFICATION/LISTINGS



### 3.0 SPECIFICATIONS – MATERIAL

#### Housing:

Ductile iron conforming to ASTM A-536, grade 65-45-12, painted Orange Enamel. Ductile iron conforming to ASTM A-395, grade 65-45-15, is available upon special request.

Optional: Hot dipped galvanized.

#### Outlet: NPT

Optional: BSPT

ALWAYS REFER TO ANY NOTIFICATIONS AT THE END OF THIS DOCUMENT REGARDING PRODUCT INSTALLATION, MAINTENANCE OR SUPPORT.


System No.		Location	
Submitted By		Date	

Spec Section		Paragraph	
Approved		Date	



## 4.0 DIMENSIONS

### No.67



Nominal Size inches DN		C to GE		C to TE		Approximate Weight (Each)	
		inches	mm	inches	mm	lb	kg
1 ¼ DN32	x ½ DN15	1.875	48	1.38	35	0.6	0.3
	¾ DN20	1.875	48	1.38	35	0.5	0.2
	1 DN25	2	51	1.75	44	0.6	0.3
1 ½ DN40	x ½ DN15	1.875	48	1.5	38	0.7	0.3
	¾ DN20	1.875	48	1.5	38	0.7	0.3
	1 DN25	2	51	1.625	41	0.7	0.3
2 DN50	x ½ DN15	1.875	48	1.75	44	0.7	0.3
	¾ DN20	1.875	48	1.75	44	0.7	0.3
	1 DN25	2	51	1.75	44	0.9	0.4
2 ½ DN65	x ½ DN15	1.875	48	2	51	1.3	0.6
	¾ DN20	1.875	48	2	51	1.2	0.6
	1 DN25	2	51	2	51	1.3	0.6
3 DN80	x ¾ DN20	2	51	2.375	60	2.0	0.9
	1 DN25	2	51	2.375	60	1.9	0.9

## 5.0 PERFORMANCE

Please see applicable coupling publication for performance, or contact Victaulic for more information.

## 6.0 NOTIFICATIONS

### WARNING



- **This product must be installed by an experienced, trained installer, in accordance with the instructions provided with each valve. These instructions contain important information. Failure to follow these instructions may result in serious personal injury, property damage, or valve leakage.**

**If you need additional copies of this product literature or the valve installation instructions, or if you have any questions about the safe installation and use of this device, contact Victaulic Company, P.O. Box 31, Easton, PA 18044-0031 U SA, Telephone: 001-610-559-3300.**

## 7.0 REFERENCE MATERIALS

[10.64: FireLock EZ™ Style 009N Rigid Coupling](#)

### User Responsibility for Product Selection and Suitability

Each user bears final responsibility for making a determination as to the suitability of Victaulic products for a particular end-use application, in accordance with industry standards and project specifications, and the applicable building codes and related regulations as well as Victaulic performance, maintenance, safety, and warning instructions. Nothing in this or any other document, nor any verbal recommendation, advice, or opinion from any Victaulic employee, shall be deemed to alter, vary, supersede, or waive any provision of Victaulic Company's standard conditions of sale, installation guide, or this disclaimer.

### Intellectual Property Rights

No statement contained herein concerning a possible or suggested use of any material, product, service, or design is intended, or should be construed, to grant any license under any patent or other intellectual property right of Victaulic or any of its subsidiaries or affiliates covering such use or design, or as a recommendation for the use of such material, product, service, or design in the infringement of any patent or other intellectual property right. The terms "Patented" or "Patent Pending" refer to design or utility patents or patent applications for articles and/or methods of use in the United States and/or other countries.

### Note

This product shall be manufactured by Victaulic or to Victaulic specifications. All products to be installed in accordance with current Victaulic installation/assembly instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.

### Installation

Reference should always be made to the Victaulic installation handbook or installation instructions of the product you are installing. Handbooks are included with each shipment of Victaulic products, providing complete installation and assembly data, and are available in PDF format on our website at [www.victaulic.com](http://www.victaulic.com).

### Warranty

Refer to the Warranty section of the current Price List or contact Victaulic for details.

### Trademarks

*Victaulic* and all other Victaulic marks are the trademarks or registered trademarks of Victaulic Company, and/or its affiliated entities, in the U.S. and/or other countries.